

# Certificate of Compliance

Certificate Number 20050325-E154860  
Report Reference E154860, 1994 January 20  
Issue Date 2005 March 25

Page 1 of 1



**Underwriters  
Laboratories Inc.®**

*Issued to:* **R S G INC**

Po Box 849  
Lakewood CA 90714

*This is to certify that  
representative samples of*

## **Fire Alarm Devices for use in Hazardous Locations**

Fire alarm/initiating station, Model Nos. RMS-EX-WP-1T, -2T, -3T or -6T, with or without Suffix DAH, KL or LP, for use in Class I, Groups B, C and D; Class II, Groups E, F and G hazardous locations.

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:*


UL 1203 Explosion-Proof and Dust-Ignition-Proof Electrical Equipment  
for Use in Hazardous (Classified) Locations

*Additional Information:*

Marking shall include the Manufacturer's name, Model number, Hazardous location Classes and Groups, Electrical rating, Caution statement and may also be marked type 4X.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:

 with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by: *Kamakshi Patel*  
Kamakshi Patel / Conformity Assessment Spec  
Underwriters Laboratories Inc.

Reviewed by: *Paul Kelly*  
Paul Kelly / Operations Manager  
Underwriters Laboratories Inc.