



UJPX.E78316 Signal Appliances, Miscellaneous for Use in Hazardous Locations

[Page Bottom](#)

Signal Appliances, Miscellaneous for Use in Hazardous Locations

[See General Information for Signal Appliances, Miscellaneous for Use in Hazardous Locations](#)**TOMAR ELECTRONICS INC**

E78316

2100 W OBISPO AVE
GILBERT, AZ 85233 USA

Class I, Groups C and D; Class II, Groups E, F and G.

Strobe lights, Models 3150BEP, 3200BEP, 3300BEP followed by FM, FM-1, PM, PM-1, WM or WM-1, followed by A, B, C, G or R, may be followed by BEPG ; Model Series 3150, rated 12 thru 74 vdc; Series 3200, rated 120 vac, 50/60 hz; Series 3300, rated 240 vac, 50/60 hz.

Model 7024BEP or 7120BEP followed by FM, FM-1, PM, PM-1, WM or WM-1 may be followed by EPG or SEPG, rated 12 vdc through 28 vdc or 120 vac, respectively. Also for use in marine locations.

LED strobe lights, Models 3024XL, 3124XL, 7024XL, 7124XL followed by FM, FM-1, PM, PM-1, WM or WM-1, followed by A,B, C, G, R or M may be followed by EPG. Models 3024XL and 7024XL rated 12-36 vdc and Models 3124XL and 7124XL rated 120-240 vac, 50/60 hz. (+).

Class I, Groups A, B, C and D, Division 2; Class II, Groups F and G, Division 2; Class III.

Strobe lights, Models 4375-120/240, 4375-1274, rated 12 thru 74 vdc or 120 thru 240 vac, 60 hz, respectively.

Model 490S-1280T, rated 12 thru 80 vdc, 16 thru 24 vac, 50/60 hz.

Model 490S-120T, rated 120 vac, 50/60 hz.

+ - Also Listed as Marine Visual-signal Devices (UXUB) under complementary Listing program.

[Last Updated](#) on 2008-04-25[Questions?](#)[Print this page](#)[Notice of Disclaimer](#)[Page Top](#)[Copyright © 2011 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

