

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-2238:0500 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Tomar Electronics, Inc. 2100 W Obispo Ave., Gilbert, AZ 85233
Contact: Bob Layton (480) 497-4400 Ext: 222
Email: robert.layton@tomar.com

DESIGN: Tomar Electronics Models 3150BEP, 3200BEP, and 3300BEP strobe light for use in hazardous locations; Ceiling, Pendant, or Bracket mounted; Amber, Blue, Clear, Green, or Red lens; with or without guard. Class I, Groups C & D; Class II, Groups E, F, & G; Class III.

RATING: 3150BEP - 12VDC to 74VDC
3200BEP 120VAC 50/60Hz
3300BEP 240VAC 50/60Hz

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, hazardous location class, and UL label.

APPROVAL: Listed as a visible notification appliance for use with separately listed compatible fire alarm control units for indoor or outdoor use. Refer to listee's Installation Instruction Manual for details.

11-1-2016 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **November 03, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division