



Certificate of Compliance

Certificate: 70027019

Master Contract: 174186

Project: 70027019

Date Issued: 8/4/2015

Issued to: Tomar Electronics Incorporated
2100 W. Obispo Ave.
Gilbert, AZ 85233-3401
USA
Attention: Bob Layton

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Khushboo Patel
Issued by: Khushboo Patel

PRODUCTS

CLASS 3428 83 - FIXTURES AND FITTINGS - For Hazardous Locations-Certified to U.S. Standards

CLASS 3428 03 - FIXTURES AND FITTINGS - For Hazardous Locations

Class I, Div 1, Groups C and D, Class II, Division 1, Groups E, F and G; Class III, T6

LED luminaire model TLX7240 rated at 120/240 Vac, 50/60 Hz 0.56A/0.33A, Max ambient temperature 60 C

APPLICABLE REQUIREMENTS

C22.2 No. 30-M1986 (R2012) - Explosion-proof enclosures for use in class I hazardous locations
C22.2 No. 25-1966(R2014) - Enclosures for Use in Class II Groups E, F, and G Hazardous Locations
CSA 137-M1981 (R2014) - Electric Luminaires for Use in Hazardous Locations
ANSI/UL 844-2012 - Luminaires for Use in Hazardous (Classified) Locations
UL 8750(1st Ed.) - Light Emitting Diode (LED) Equipment for Use in Lighting Products
CSA 250.13-14 Light emitting diode (LED) equipment for lighting applications